





Primary Markings	H0-H1-H2-H3
Primary Terminals	Terminal Blocks
Secondary Voltage	208Y/120
Secondary Max Current	25A
Secondary Markings	X0-X1-X2-X3
Secondary Terminals	Terminal Blocks
Primary Taps	+/- 1 x 5%
Conductor Material	Copper
Insuation Class	220°C
BIL (Insulation) Level	10kV
Impedance	5.0 – 6.5%
Sound (db)	40
Enclosure Type	NEMA 3R Indoor
Enclosure	E3R-4
Finish	Polyster Powder Coat – ANSI/ASA 61 Grey
Standards & Certifications	CSA Certified File No. LR34493, UL Listed File No. E108255, ISO 9001:2015 Registered
Efficiency	N/A