





Primary Terminals	#2-14 AWG
Secondary Voltage	110/220
Secondary Max Current	45.5A
Secondary Markings	X1-X3-X2-X4
Secondary Terminals	#2-14 AWG
Primary Taps	+/- 1 x 5%
Conductor Material	Copper
Insulation Class	220°C
BIL (Insulation) Level	10kV
Impedance	5.5 – 7.0%
Sound (db)	40
Enclosure Type	NEMA 1
Enclosure	E1-2
Finish	Polyster Powder Coat – ANSI/ASA 61 Grey
Standards & Certifications	CSA Certified File No. LR34493, UL Listed File No. E108255, ISO 9001:2015 Registered