



Diagram illustrating a 1D chain structure with three sites labeled $H0/X0$, $X1$, and $H1$. The sites are connected by a series of horizontal lines, with the central $X1$ site having a double line above it.

Page: 1



PRODUCT SPECIFICATIONS

Weight	86.4 lbs
Phases	1
kVA	50
Connection	1PhA-NT-1
Primary Voltage	400
Primary Max Current	72.2A
Primary Markings	X0-X1
Primary Terminals	#2-14 AWG
Secondary Voltage	440
Secondary Max Current	65.6A
Secondary Markings	H0-H1
Secondary Terminals	#2-14 AWG
Primary Taps	N/A
Conductor Material	Copper
Insulation Class	220°C (Class H)
BIL (Insulation) Level	10kV
Efficiency (@35% Load) %	N/A
Impedance Range	0.5 – 1.5%
Sound (db)	40 dB
Enclosure Type	NEMA 1
Enclosure Size	E1-2
Finish/Colour	Polyester Powder Coat – ANSI/ASA 61 Grey
Standards & Certifications	CSA Certified File No. LR34493, UL Listed File No. E108255, ISO 9001:2015 Registered



OFFICIAL QUOTE

50KVA 400 VOLTS TO 440 VOLTS
SINGLE PHASE AUTOTRANSFORMER



Country/Manufacturer	Canada/RPM
----------------------	----------------------------