





Secondary Terminals	Terminals
Primary Taps	N/A
Conductor Material	Copper
Temperatue Rise	80°C
Insuation Class	130°C
BIL (Insulation) Level	10kV
Efficiency	N/A
Impedance	5.0 – 7.0%
Sound (db)	40
Enclosure Type	Core & Coil
Enclosure	See Chart
Standards & Certifications	CSA Certified File No. LR34493, UL Listed File No. E110286, ISO 9001:2015 Registered
Finish	N/AN/A