





Primary Terminals	#2-14 AWG
Secondary Voltage	120/240
Secondary Max Current	83.3A
Secondary Markings	X1-X3-X2-X4
Secondary Terminals	#2-14 AWG
Primary Taps	+/- 2 x 2.5%
Conductor Material	Copper
Insulation Class	220°C
BIL (Insulation) Level	10kV
Impedance	5.0 – 6.5%
Sound (db)	45
Enclosure Type	NEMA 3R Indoor
Enclosure	E3R-4
Finish	Polyster Powder Coat – ANSI/ASA 61 Grey
Standards & Certifications	CSA Certified File No. LR34493, UL Listed File No. E108255, ISO 9001:2015 Registered
Efficiency	N/A