




Page: 1



| | |
|----------------------------|--|
| Primary Terminals | #2-14 AWG |
| Secondary Voltage | 600 |
| Secondary Max Current | 8.3A |
| Secondary Markings | H1-H2 |
| Secondary Terminals | #2-14 AWG |
| Primary Taps | +/- 1 x 5% |
| Conductor Material | Copper |
| Insulation Class | 220°C |
| BIL (Insulation) Level | 10kV |
| Impedance | 5.5 – 7.0% |
| Sound (db) | 40 |
| Enclosure Type | NEMA 1 |
| Enclosure | E1-2 |
| Finish | Polyster Powder Coat – ANSI/ASA 61 Grey |
| Standards & Certifications | CSA Certified File No. LR34493, UL Listed File No. E108255, ISO 9001:2015 Registered |